

Questions on RFB received to date with answers:

What size office do you want? We do not have a set size. We are limited by our funding for this project.

Do you have architectural plans? We do not. We are issuing this RFB as a design/build RFB.

Do you want skylights? No skylights.

Do you want entire building insulated? Yes

Do you want individual offices/how many? We are fine with an open concept with no individual offices but will accept bids for office plans with individual offices.

Kitchen area details-range (stove/oven)? Kitchen area requests are for sink, cabinets and water hookup for a refrigerator/freezer. No stove/range/oven is requested.

What is the garage door height? Our F250 is just under seven foot tall. We would like the office to be built out of nine foot studs to allow a taller garage door for the F250.

Notation: We are requesting that the refrigerated air unit be located on a pad on the ground, not installed on the roof.